

CAPACITÉS RÉSERVÉES

BEAUPORT

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-E-18-37	0.001	0.001
R-E-18-36	0.001	0.001
R-E-18-35	0.001	0.001
R-E-18-34	0.001	0.001
R-1-E-18-33	0.001	0.001
R-E-18-31-19	0.001	0.001
R-E-18-31-18	0.001	0.001
R-E-18-31-17	0.001	0.001
R-E-18-31-13	0.001	0.001
R-1-E-18-31-10	0.001	0.001
R-2-E-18-31-10	0.005	0.005
R-E-18-31-6	0.002	0.002
R-E-18-31-2	0.001	0.001
R-E-18-13	0.001	0.001
TOTAL	1.058	12.806

CAPACITÉS RÉSERVÉES

BEAUPORT

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-1-E-12-46	0.002	0.002
R-E-12-39	0.004	0.004
R-E-12-34	0.006	0.006
R-E-12-24	0.046	0.046
R-E-12-19	0.005	0.010
R-E-12-14A	0.033	0.069
R-1-E-106	0.050	0.180
R-2-E-106	0.001	0.004
R-E-105	0.056	0.056
R-E-102	0.022	0.043
R-E-87	0.010	0.028
R-E-83	0.002	0.002
R-E-82	0.002	0.002
R-E-80	0.001	0.001
R-E-77	0.001	0.001
R-E-76	0.006	0.006
R-E-74	0.002	0.002
R-E-72	0.001	0.001
R-E-71	0.017	0.020
R-E-66	0.001	0.019
R-E-57	0.002	0.003
R-E-54	0.003	0.005
R-E-53	0.004	0.006
DÉRY	0.123	6.014
R-E-42	0.007	0.007
R-E-39	0.006	0.009
DE-LA-STATION	0.059	1.329
R-E-36	0.007	0.014
R-E-35	0.001	0.001
R-1-E-32	0.001	0.001
R-2-E-32	0.001	0.001
R-E-22	0.084	4.013
R-1-E-65-27	0.043	0.122
R-2-E-65-27	0.001	0.003
R-E-65-18-A	0.013	0.013
R-1-E-65-3	0.007	0.022
R-2-E-65-3	0.010	0.032
R-E-18-93	0.096	0.152
R-E-18-88	0.031	0.048
R-E-18-87	0.001	0.001
R-E-18-85	0.013	0.020
R-1-E-18-84	0.005	0.006
R-2-E-18-84	0.018	0.033
R-E-18-77	0.062	0.145
R-E-18-72	0.002	0.003
R-E-18-70	0.108	0.184
R-E-18-67	0.008	0.008
R-E-18-52	0.042	0.042
R-E-18-42	0.002	0.002
R-E-18-41	0.002	0.005
R-E-18-40	0.007	0.039
R-E-18-39	0.001	0.001
R-E-18-38	0.001	0.001

CAPACITÉS RÉSERVÉES

CAP ROUGE

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-1-O-5-10	0.068	0.098
R-2-O-5-10	0.046	0.055
R-O-5-6	0.001	0.001
R-1-O-5-4-2	0.001	0.001
R-2-O-5-4-2	0.030	0.099
TOTAL	0.145	0.254

CAPACITÉS RÉSERVÉES

CHARLESBOURG

RACCORDEMENTS	DÉBIT RÉSERVÉ	
	2011	
	SEC	PLUIE
	m3/s	m3/s
R-1-O-336	0.001	0.001
R-2-O-336	0.022	0.022
R-1-O-328	0.005	0.005
R-2-O-328	0.002	0.002
R-O-298	0.001	0.001
R-O-295	0.001	0.001
R-O-284	0.004	0.004
R-O-272	0.002	0.002
R-O-264	0.001	0.001
R-O-261	0.001	0.001
R-O-260	0.019	0.020
R-O-259	0.001	0.001
R-O-257	0.001	0.001
R-O-255	0.001	0.001
R-O-254	0.020	0.020
R-O-252	0.008	0.011
R-O-249	0.001	0.001
R-O-248	0.003	0.003
R-O-246	0.004	0.004
R-O-245-A	0.002	0.002
R-O-245	0.001	0.001
R-O-244	0.003	0.003
R-O-243	0.005	0.006
R-O-242	0.002	0.003
R-1-O-240	0.001	0.001
R-2-O-240	0.001	0.002
R-O-232	0.001	0.001
R-1-O-222	0.006	0.006
R-2-O-222	0.024	0.038
R-O-210	0.031	0.031
R-O-271-35	0.078	0.178
R-O-271-4	0.001	0.001
R-1-O-271-3	0.002	0.002
R-2-O-271-3	0.004	0.004
TOTAL OUEST	0.258	0.376
R-1-E-12-85	0.090	0.230
R-2-E-12-85	0.001	0.002
R-E-12-84	0.006	0.006
R-E-12-79	0.013	0.013
R-E-12-75	0.002	0.005
R-E-12-63	0.006	0.017
R-E-12-61	0.002	0.003
R-1-E-12-57	0.064	0.080
R-2-E-12-57	0.025	0.037
R-E-12-52	0.007	0.007
R-2-E-12-46	0.003	0.003
R-E-12-35	0.014	0.097
R-E-12-31	0.084	0.192
R-E-12-26-32	0.027	0.027
R-E-12-26-28	0.019	0.019
R-E-12-26-22	0.025	0.025
R-E-12-26-20	0.003	0.003
R-E-12-26-15	0.049	0.049
R-E-12-26-12	0.003	0.003
R-E-12-26-6	0.119	0.290
R-E-18-31-20	0.025	0.091
TOTAL EST	0.586	1.198
TOTAL EST-OUEST	0.844	1.575

CAPACITÉS RÉSERVÉES

L'ANCIENNE LORETTE

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-O-64-43	0.002	0.005
R-1-O-64-41	0.004	0.011
R-2-O-64-41	0.002	0.007
R-O-64-38	0.007	0.020
R-O-64-35	0.013	0.019
R-O-64-34	0.001	0.001
R-O-64-32	0.003	0.041
R-O-64-29	0.002	0.027
R-O-64-27	0.001	0.010
R-O-64-26	0.001	0.009
R-O-64-23	0.007	0.097
R-O-64-21	0.038	0.040
R-O-64-20	0.001	0.001
R-O-64-17	0.001	0.001
R-1-O-64-15	0.001	0.002
R-2-O-64-15	0.004	0.013
R-1-O-64-7	0.069	0.418
R-2-O-64-7	0.003	0.019
R-O-64	0.001	0.003
R-O-60	0.026	0.061
R-O-57	0.013	0.031
R-O-47	0.030	0.069
R-O-41	0.003	0.004
R-O-40-A	0.001	0.001
R-O-47-3	0.046	0.209
R-O-84	0.024	0.024
TOTAL	0.303	1.141

CAPACITÉS RÉSERVÉES

LAC SAINT-CHARLES

RACCORDEMENTS	DÉBIT RÉSERVÉ		
C.U.Q.	2011		
	SEC	PLUIE	FONTE DE NEIGES
	m3/s	m3/s	m3/s
R-O-202-26	0.118	0.119	0.235
TOTAL	0.118	0.119	0.235

CAPACITÉS RÉSERVÉES

LORETTEVILLE

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-O-149-64-A	0.001	0.001
R-O-149-64	0.001	0.001
R-O-149-63	0.001	0.001
R-O-149-62	0.001	0.001
R-1-O-149-61	0.001	0.001
R-2-O-149-61	0.013	0.014
R-O-149-59	0.001	0.001
R-O-149-55-A	0.001	0.001
R-O-149-51	0.001	0.001
R-O-149-48	0.001	0.001
R-O-149-39	0.003	0.003
R-O-149-36	0.005	0.007
R-O-149-29	0.022	0.031
R-O-149-3	0.031	0.100
R-O-140-A	0.025	0.055
R-1-O-138	0.001	0.001
R-2-O-138	0.019	0.720
R-O-132	0.086	2.452
R-O-129-A	0.064	0.118
TOTAL	0.278	3.510

CAPACITÉS RÉSERVÉES

QUÉBEC

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
LEBOURNEUF		
R-E-12-26-73	0.044	0.044
R-E-12-26-69-22	0.048	0.049
R-E-12-26-69-8	0.008	0.007
R-E-12-26-68	0.005	0.005
R-E-12-26-57	0.009	0.009
R-E-12-26-52	0.061	0.102
R-E-12-26-48	0.023	0.023
R-1-E-12-26-38	0.001	0.001
R-2-E-12-26-38	0.031	0.031
SAINT-PASCAL		
R-E-16	0.001	0.001
R-E-12-14	0.001	0.001
R-E-12-4	0.001	0.001
R-E-9	0.001	0.001
CHAMPFLEURY	0.219	6.542
NORD OUEST		
R-E-3-34-23-1	0.002	0.002
R-E-3-34-18	0.002	0.002
R-E-3-34-10	0.002	0.002
R-E-3-34-9	0.006	0.155
R-E-3-34-6	0.007	0.188
R-E-3-34-4	0.257	6.622
SE-12		
TOTAL	0.257	3.622
REG. PR.-EDOUARD	1.310	2.820
REG. ST-ROCH	0.950	3.695
ST-ANDRÉ		
R-E-3-7-4 (SST)	0.278	0.616
R-E-3-7-10	0.001	0.001
R-E-3-7-15	0.001	0.001
R-E-3-7-17	0.001	0.001
R-E-3-7-20	0.001	0.001
R-E-3-7-23	0.001	0.001
R-E-3-7-24	0.001	0.001
R-E-3-7-26	0.084	0.085
LIMOILLOU		
POSTE LIMOILLOU	2.094	10.999
TOTAL EST	2.547	15.401

CAPACITÉS RÉSERVÉES

QUÉBEC

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-O-213	0.004	0.004
R-O-174	0.003	0.003
R-O-170	0.004	0.004
R-O-163	0.012	0.012
R-O-155	0.004	0.004
R-1-O-149-66	0.001	0.001
R-2-O-149-66	0.005	0.007
R-O-128	0.007	0.013
R-O-127	0.003	0.005
R-O-122	0.108	0.178
R-O-80-36	0.077	0.124
R-O-80-16	0.047	0.053
R-O-47-2	0.046	0.120
R-O-4-43	0.215	0.329
R-1-O-4-42-1	0.015	0.014
R-O-114-44	0.001	0.001
R-O-4-1-74	0.029	1.994
TOTAL OUEST	0.581	2.866
TOTAL EST-OUEST	3.128	18.267

CAPACITÉS RÉSERVÉES

SAINT-AUGUSTIN

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-O-23-89	0.143	0.164
R-O-23-36-6	0.059	0.059
R-2-O-23-36	0.009	0.009
TOTAL	0.211	0.232

CAPACITÉS RÉSERVÉES

SAINT-ÉMILE

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
R-O-202-25	0.012	0.012
R-O-202-16-A	0.011	0.011
R-O-194	0.043	0.043
R-O-187	0.013	0.013
R-O-183	0.001	0.001
R-O-178	0.031	0.031
TOTAL	0.111	0.111

CAPACITÉS RÉSERVÉES

SAINTE-FOY

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
ROSS		
R-O-4-1-19-3	0.145	7.113
LONGCHAMP		
R-O-4-1-18-5	0.163	5.615
DIJON		
R-O-4-1-13	0.078	0.272
R-O-4-1-12-A	0.062	0.062
VERSANT NORD		
R-2-O-4-42-1	0.010	0.010
R-1-O-4-41	0.140	0.229
R-2-O-4-41	0.056	0.094
R-1-O-4-35	0.001	0.001
R-2-O-4-35	0.001	0.001
R-3-O-4-35	0.130	0.460
R-O-4-26	0.004	0.004
R-O-4-25	0.143	0.210
R-O-4-24	0.002	0.002
R-O-4-19	0.003	0.003
R-O-4-18	0.001	0.001
R-O-4-15	0.147	0.279
R-O-4-10	0.001	0.001
R-O-4-8	0.001	0.001
R-O-4-1-5	0.182	0.652
CHAUVEAU		
R-O-64-44	0.028	0.068
CHAMPIGNY		
R-O-38	0.004	0.006
R-O-34	0.001	0.001
R-O-31	0.015	0.063
R-O-29	0.015	0.015
R-O-26	0.001	0.001
R-O-25	0.001	0.001
R-O-22	0.013	0.013
R-O-20	0.001	0.001
R-O-15	0.019	0.019
R-O-7	0.116	0.166
R-O-23-45	0.001	0.001
R-1-O-23-36	0.004	0.004
R-1-O-23-29-4	0.002	0.029
R-2-O-23-29-4	0.006	0.069
R-2-O-23-29	0.008	0.018
R-O-23-16	0.008	0.110
R-O-23-11	0.002	0.002
R-O-23-8	0.005	0.021
R-O-23-7	0.001	0.001
R-O-23-4	0.001	0.001
TOTAL	1.522	15.620

CAPACITÉS RÉSERVÉES

VILLE : SILLERY

BASSIN	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
POSTE 11 R-O-4-1-20	0.080	3.329
R-O-4-1-64	0.001	0.001
DU RAVIN R-O-4-1-63-4	0.004	0.146
COULONGE R-O-4-1-61-2	0.266	2.549
LEMOYNE R-O-4-1-55-2	0.026	1.204
BEAULIEU R-O-4-1-44-3	0.031	1.491
DE L'ÉGLISE R-O-4-1-24-3	0.011	0.712
POSTE 10 R-O-4-1-22-1	0.023	0.023
ST-LOUIS R-O-4-1-21-18	0.030	1.753
AUGUSTINES R-O-4-1-21-1-2	0.070	1.384
R-O-4-1-21-2	0.001	0.001
TOTAL	0.542	12.592

CAPACITÉS RÉSERVÉES

VAL BÉLAIR

RACCORDEMENTS	DÉBIT RÉSERVÉ		
C.U.Q.	2011		
	SEC	PLUIE	FONTE DE NEIGES
	m3/s	m3/s	m3/s
R-O-114-98	0.054	0.065	0.193
R-O-114-92	0.004	0.004	
R-O-114-86	0.021	0.021	
R-O-114-83	0.008	0.008	
R-O-114-82	0.005	0.005	
R-O-114-81-A	0.008	0.030	
R-O-114-81	0.009	0.009	
R-O-114-80	0.004	0.030	
R-O-114-78	0.008	0.008	
R-O-114-77-A	0.002	0.002	
R-O-114-77	0.008	0.008	
R-1-O-114-75	0.026	0.026	
R-2-O-114-75	0.001	0.001	
R-O-114-74	0.002	0.002	
R-O-114-73	0.006	0.006	
R-O-114-72	0.010	0.010	
R-O-114-71	0.001	0.001	
R-O-114-70	0.010	0.010	
R-O-114-69	0.003	0.003	
R-O-114-67	0.002	0.002	
R-O-114-65-A	0.001	0.002	
R-O-114-58	0.044	0.055	
R-O-114-52	0.008	0.008	
R-O-114-51	0.070	0.072	
R-O-114-40	0.001	0.001	
R-O-114-36	0.004	0.004	
R-O-114-34	0.028	0.041	
R-O-114-31	0.001	0.001	
R-O-114-28	0.027	0.022	
TOTAL	0.375	0.457	0.193

CAPACITÉS RÉSERVÉES

VANIER

RACCORDEMENTS	DÉBIT RÉSERVÉ	
C.U.Q.	2011	
	SEC	PLUIE
	m3/s	m3/s
# 25 CUQ R-E-3-34-11-6	0.087	0.193
CHAN.-COTÉ R-E-3-34-23-2	0.034	0.990
P.-BERTRAND R-E-3-34-35	0.029	1.777
R-E-3-34-31	0.001	0.009
R-E-3-34-27	0.002	0.032
TOTAL	0.153	3.001